

Annexure- C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 11/26

Dated: 30.05.2026

It is certified that an inspection team headed by MR. VIKAS KUMAR..... TECHNICAL MANAGER.....
(Name of Officers with designation) from U.P. Jal Nigam (Rural), Ambedkar Nagar... PHED
inspected the **Maharani Geeta Devi Educational Centre, Malipur (Mansoorpur), Jalalpur, Ambedkar Nagar** on 29.05.2026..... (date of inspection) and on the basis of Water Test Report
(Attached) bearing no Chemical test / M2305.2026.01/26-27 dated 30.05.2026... of U.P. Jal Nigam (Rural)..
(PHED Lab) certified that the **Maharani Geeta Devi Educational Centre** has safe drinking water
facilities for the students and members of staff of the institution. The school also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/State/ U.T. Govt.

This certificate is valid till 30.05.2027.....

Signature with Seal: Vikas Kumar
Technical Manager
District Level Water Analysis Laboratory
UPJN Ambedkar Nagar

Name: Vikas Kumar.....

Designation : Technical Manager.....

Name & Address of the Office/Department: U.P. Jal Nigam (Rural), Ambedkar Nagar

To,
Principle of.....

Maharani Geeta Devi Educational Centre
Malipur (Mansoorpur), Jalalpur, Ambedkar Nagar

Note: The certificate is to be issued by authorized officer/ PHED Lab/local bodies



TEST REPORT
DISTRCT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR



ULR NO-TC172172600000102F

Report No- Chemical Test/ 2905202601/2026-27 Date 30.05.2026 S.No -01 SAMPLE CODE M2905202601

Customer Details- Maharani Geeta Devi Educational Centre Malipur Mansoorpur Ambedkar Nagar

Office Name and Address Office of excutive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gali,Akbarpur,District-Ambedkar Nagar ,Pin-224122

Ref Letter No & Date NA

Basic details of sample

District	AMBEDKAR NAGAR	Block	AKBARPUR
Gram Panchayat	MALIPUR	Village	MANSOORPUR
Habitation	M.G.DEVI EDUCATIONAL CENTRE	Location	KHAS
Water Source	BORWELL	Sample No.	1
Quantity of Sample	1 L	Date of S.C.	29.05.2026
Receiving Date	29.05.2026	S. Collector	SELF
Sample Depositor	ABHISHEK I VERMA	S.Method	IS 47614 (PART-05)-2021
Analysis Start Date	29.05.2026	Analysis Completion Date	30.05.2026

Environmental Condition

Temperature 25± 3 °C Relative Humidity 50%±15%

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measure ment	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Odour	NA	Agre	Agreeable	Agreeable	IS 3025(Part 05):2018
2	Taste	NA	Agre	Agreeable	Agreeable	IS 3025(Part 8):2023
3	Colour	HU	10.00	5	15	IS 3025(Part 04):2021
4	pH	NA	7.23	6.50	8.50	IS 3025(Part 11):2022
5	Turbidity	NTU	4.51	1	5	IS 3025(Part 10):2023
6	TDS	mg/L	302.00	500	2000	IS 3025(Part 16):2023
7	Alkalinity	mg/L	252.00	200	600	IS 3025(Part 23):2023
8	Chloride	mg/L	20.00	250	1000	IS 3025(Part 32):2019
9	Hardness	mg/L	220.00	200	600	IS 3025(Part 21):2023
10	Calcium	mg/L	124.54	75	200	IS 3025(Part 40):2024
11	Magnesium	mg/L	36.28	30	100	APHA 24rd Edition -3500 Mg By Calculation Method
12	Sulphate	mg/L	26.12	200	400	IS 3025(Part 24):2022
13	Nitrate	mg/L	0.56	0	45	APHA 24rd EDITION -3500 NO3-B method
14	Fluoride	mg/L	0.21	1	1.5	IS 3025(Part 60):2023
15	Iron	mg/L	0.56	0	1	IS 3025(Part 53):2024

1.Statment of conformity N/A
 2.Reporting opinions and interpretations ISO 17025 N/A

Note:-
 1.Source is not varified by the laboratory.
 2. This Certificate refers only to the particular sample(s) submitted for testing.
 3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 5. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
 Prepared By

Authorized Signatory
 VIKAS KUMAR
 Technical Manager

**End of Test Report **

Laboratory Contact details- Mob-9981490366

Email-eeupjn.cdambedkarnagar@gmail.com

District Level Water Analysis Laboratory
 UPJN Ambedkar Nagar



TEST REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR

(Non NABL
Accredited
parameter)

Report No- Chemical Test/ 2905202601/2026-27 Date 30.05.2026 S.No -01 SAMPLE CODE M2905202601

Customer Details- Maharani Geeta Devi Educational Centre Malipur Mansoorpur Ambedkar Nagar

Office Name and Address Office of excutive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gali,Akbarpur,District-Ambedkar Nagar ,Pin-224122

Ref Letter No & Date NA

Basic details of sample

District	AMBEDKAR NAGAR	Block	AKBARPUR
Gram Panchayat	MALIPUR	Village	MANSOORPUR
Habitation	M.G.DEVI EDUCATIONAL CENTRE	Location	KHAS
Water Source	BORWELL	Sample No.	1
Quantity of Sample	1 L	Date of S.C.	29.05.2026
Receiving Date	29.05.2026	S. Collector	SELF
Sample Depositor	ABHISHEK I VERMA	S.Method	IS 17614 (PART-05)-2021
Analysis Start Date	29.05.2026	Analysis Completion Date	30.05.2026

Environmental Condition


Temperature	25± 3 °C	Relative Humidity	50%±15%
-------------	----------	-------------------	---------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
16	Free Residual Chlorine	mg/L	0.00	0.2	1	IS 3025(Part-26):2004
17	E.coli	H2S Vials	0.00	0	0	H2S Vials
1.Statment of conformity						N/A
2.Reporting opinions and interpretations ISO 17025						N/A

Note:-
1. Source is not varified by the laboratory.
2. This Certificate refers only to the particular sample(s) submitted for testing.
3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
5. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By


Authorized Signatory
VIKAS KUMAR

Technical Manager
Technical Manager

**End of Test Report **

District Level Water Analysis Laboratory
UPJN Ambedkar Nagar